

Mill Test Certificate

Bri-Steel Manufacturing Inc. 2125-64 Avenue, Edmonton, AB Canada T6P 1Z4

Fax: 001 (780) 469-6986 Tel: 001 (780) 469-6603

www.brichemsteel.com

Product: Seamless Carbon Steel Pipe

Product Heat Number:

BSM-1336 Product Size: 16 SCH 100

Production Date: Oct 17, 2013

Production Method: Hot Expansion

Product Heat Treatment: As-rolled

Certificate No.: MTR- 000549

Product Standards: ASME B36.10-2004, ASTM/ASME A/SA106-2011 Grade B/C NDE, A/SA53-2012 Grade B Type S, NACE MR0175-2009 MR0103-2010

Product Markings

SANUFACTURE NPS 16 SCH 100 1.031 INCHWT SMLS 2013/10 NDE

MANUFACTURE NEAT BSM-1336 (PIPE # LENGTH MASS) 164.8Ib/ft ASTM/ASME A/SA106 GR B/C A/SA53 GR B NACE MR0175/MR0103 MADE IN CANADA

B	_		Г
BSM-1336		Heat	
Heat		Test Type	
NPS 16 SCH 100 1.031in. WT		Product Size	Product: Details
1		Pieces	
DRL		Length	
164.8	lb/ft	Mass	
Ġ	μR/hr	Geiger	
<10	Gauss	Res. Mag.	
Pass	Insp.	Visual	
Pass		OD	No
Pass	WT	TU	Non-Destructive Testing
Pass	ASTM E213 ASTM	TU	ive Testing
Pass	ASTM	ET	
*		HydroTest	
Plain End	Condition	End	

0.39	0.39	0.0002	0.001	0.002	0.003	0.03	0.01	0.06	0.05	0.29	0.003	0.016	0.90	0.22	Product	Cogas, rully silled	
	1	0.0002	0.001	0.002	0.003	0.02	0.01	0.06	0.04	0.32	0.003	0.015	0.91	0.21	Heat	Blast Furnace; EAF; Ladle Refining; Vacuum	BSM-1336
CE(CSA)	CE(IIW)	В	Nb	Ti	<	Ni	Mo	Cu	Cr	Si	S	P	Μ'n	С	Test Type	Steelmaking Method	Heat
				-					(wt%)	al Analysis (Chemical						

BSM-1336 Heat Ferrite & Pearlite 76 HRBW Pass Longitudinal; 19.05 mm x WT 4	50mm GL	Heat Test Type Microstructure Hardness Flattening Test Tension Test Yiel	iviecnanical Properties
Pass		Flattening Test	Y
Longitudinal; 19.05 mm x WT	50mm GL	Tension Test	viechanicai Properties
49,700	psi	Yield (Rt0.5)	
72,500	psi	Tensile (Rm)	
0.69	(Rt0.5/Rm)	۲/۲	
50	%	Elongation (A)	

	BSM-1336		Heat
	336		at
	1	Standard	Test
		Sample Details	Impact Test
CHECK CONTROL OF THE PERSON OF	ū	°C	Temp
	ıı	J	
	2	J	Impact
		J	Energy
2000	1	AVG	
	t	%	1
	1	%	% Shea
200	1	%	ear
	1	AVG	
	1	mm	
The second secon	3	mm	Lateral Ex
	t	mm	ıl Expansion
	ı	AVG	

Additional Details:

- ✓ We hereby certify that this pipe product was manufactured, sampled, tested and inspected by Bri-Steel Manufacturing Inc. in results meet the corresponding requirements. accordance with ASTM/ASME A/SA106-2011 Grade B/C A/SA53-2012, and the purchase order requirements, and that the
- √ This pipe product meets the sour service requirements of NACE MR0175/ISO 15156-2:2009 Annex A2 for Region 3 Sour Service-2009 NACE MR0103-2010 Section 2.1
- ✓ No weld repairs have been performed on this product.
- \checkmark This product has not come into contact with mercury during the Bri-Steel Manufacturing processes.
- \checkmark This certificate represents a quality control system that is compliant with EN 10204:2004 Type 3.1.
- * Note that this product was hydrotested to 1000 psi for 5 seconds.

Mill Test Certificate approved by:

Sander 2013 OCT 24

Assistant QA Manager Paul Sowden, T.T.